



PROVINCIAL ELECTRICITY AUTHORITY
POWER SYSTEM STANDARD DIVISION

COPY

Specification No. : RHOT-101/2557 Leakage-current monitor

Page 1 of 1

C3 Schedule of detailed requirement

Invitation to Bid No. :

Item	PEA Material No.	Quantity	Description
1	-	set(s)	Leakage-current monitor, automatically self-test, for alert utility-line workers of over current conditions on such aerial devices as insulated ladders and truck booms with ; Display : LCD display Range : 1 to 400 microamperes, or better Resolution : not more than 1 microamperes Audible alarm : the audible warning alarm when current exceeds set point Weight (excluded battery) : not more than 5 kg Power supply : battery operate Complete with 1. One (1) coaxial cable not less than 9 m longs (2 jumpers) 2. Battery 3. Instruction manual 4. Other accessories according to manufacturer's design and auxiliary equipment necessary to complete



PROVINCIAL ELECTRICITY AUTHORITY
POWER SYSTEM STANDARD DIVISION

COPY

Specification No. : RHOT-101/2557 Leakage-current monitor

Page 1 of 1

C4 Price schedule
Invitation to Bid No. :

Manufacturer :
Trade-mark :
Country of origin :

Item	PEA Material No.	Catalogue No.	Description	Quantity	Unit Cost (See details & condition attached)	Total Cost (See details & conditions attached)
1	-		Leakage-current monitor, automatically self-test, for alert utility-line workers of over current conditions on such aerial devices as insulated ladders and truck booms with ; Display : Range : Resolution : Audible alarm : Weight (excluded battery) : kg Power supply : Complete with 1. 2. 3. 4.	set(s)		